



Model	Softener Tank	Brine Tank	Approx. Space Required inches (mm)		
	Dia. x Ht. Inches (mm)	Dia. x Ht. Inches (mm)	Height	Depth	Width
85TA-23	8 x 44 (203 x 1118)	18.1 x 34.5 (460 x 876)	48 (1219)	16 (406)	22 (559)
85TA-30	9 x 48 (229 x 1219)	18.1 x 34.5 (460 x 876)	58 (1473)	16 (406)	23 (584)
85TA-45	10 x 54 (254 x 1372)	18.1 x 34.5 (460 x 876)	64 (1626)	16 (406)	24 (610)
85TA-60	12 x 52 (305 x 1321)	20.3 x 40.5 (516 x 950)	62 (1575)	16 (406)	26 (660)
85TA-90	14 x 65 (356 x 1651)	23 x 40.5 (584 x 1029)	75 (1905)	16 (406)	28 (711)

SPECIFICATIONS	
MODEL NO.:	85TA-30
MAX. SYSTEM PRESSURE:	125 P.S.I. 862 KPa
RESIN VOLUME:	1 FT. ³ 0.028 M ³
SALT PER REGENERATION:	10 LBS. 4.55 KG.
EXCHANGE CAPACITY:	27 KILOGRAMS @ 10 lb salt
FLOW RATES: APPLICATION	5 U.S.G.P.M. 0.32 L.P.S.
PER UNIT : 15 PSI DROP	11 U.S.G.P.M. 0.69 L.P.S.
: 25 PSI DROP	15 U.S.G.P.M. 0.95 L.P.S.
MAX. FLOW TO DRAIN:	2 U.S.G.P.M. 0.13 L.P.S.
MAX. TEMPERATURE:	100 F 38 C

- NOTES:**
- SINGLE SOFTENER, METER INITIATED.
 - SOFTENER EQUIPPED WITH 85TA SERIES ELECTRONIC CONTROL VALVE WITH METER
 - PIPING MANIFOLD CAN BE CONFIGURED IN UPRIGHT POSITION (OPPOSITE OF POSITION SHOWN IN FRONT VIEW)
 - MINERAL TANKS ARE NSF/ANSI 44 CERTIFIED FOR MATERIALS AND STRUCTURAL INTEGRITY.
 - UNIT MAX. PRESSURE 125 PSI, (860 KPa), MAX. TEMP 100 F (38 C)
 - RAW WATER UPFLOW REGENERATION
 - ALL EXTERNAL PIPING, FITTINGS, VALVING SUPPLIED BY OTHERS
 - DUE TO SLIGHT EXPANSION AND CONTRACTION OF MINERAL TANK, PIPING MUST BE DESIGNED TO ALLOW SOME MOVEMENT. FLEX CONNECTORS MAY BE REQUIRED.
 - INSTALLATION OF A VACUUM BREAKER RECOMMENDED
 - 115 VOLT POWER SUPPLY STANDARD.

THIS DOCUMENT CONTAINS INFORMATION WHICH IS PROPRIETARY TO CANATURE WATERGROUP COMPANIES INC. THE REPRODUCTION, TRANSFER OR OTHER EXPLOITATION OF ANY INFORMATION CONTAINED HEREIN IS NOT PERMITTED WITHOUT PRIOR WRITTEN APPROVAL OF CANATURE WATERGROUP. THE MANUFACTURER RESERVES THE RIGHT TO MAKE PRODUCT REVISIONS WHICH MAY DEVIATE FROM THE SPECIFICATIONS AND DESCRIPTIONS STATED HEREIN WITHOUT OBLIGATION TO CHANGE PREVIOUSLY MANUFACTURED PRODUCTS OR TO NOTE THE CHANGE.



85TA SERIES DUPLEX WATER SOFTENER
1" VALVE - SYSTEM 7 TWIN ALTERNATING

PROJECT _____	DATE 3/1/16	REV _____
_____	DWG# 85TA	1